



DEPARTMENT OF THE NAVY
COMMANDER NAVY INSTALLATIONS COMMAND
716 SICARD STREET SE SUITE 1000
WASHINGTON NAVY YARD DC 20374-5140

5090
Ser N00/20U070
12 Feb 20

From: Commander, Navy Installations Command
To: Vice Chief of Naval Operations
Via: Deputy Chief of Naval Operations, Fleet Readiness and Logistics

Subj: FISCAL YEAR 2019 NAVY SHORE DRINKING WATER QUALITY REPORT

Ref: (a) OPNAV M-5090.1

Encl: (1) Navy Shore Drinking Water Quality Report for Fiscal Year 2019

1. Per reference (a), enclosure (1) is submitted.
2. Commander, Navy Installations Command (CNIC) is designated as the Navy's Executive Agent for drinking water quality ashore and is tasked by reference (a) to provide an annual report on the status of drinking water quality at Navy Shore installations, worldwide. Enclosure (1) outlines the collaborative efforts and accomplishments of Navy Installations Command, Bureau of Medicine & Surgery and Naval Facilities Engineering Command.
3. Analysis of fiscal year 2019 drinking water quality data shows that the drinking water provided at Navy installations remains safe and has continued to improve. In all cases where health-based exceedances were not resolved, and where a health risk could exist, alternate drinking water was provided to eliminate any potential health risk.
4. CNIC point of contact is CAPT Kevin Bartoe, Director, Facilities and Environmental (N4), (202) 433-4353, kevin.bartoe@navy.mil.

A handwritten signature in black ink, appearing to read "M. M. Jackson", is positioned above the printed name.

M. M. JACKSON

Copy to:
BUMED FALLS CHURCH VA
COMNAVFACENGCOM WASHINGTON DC

This Page Intentionally Left Blank

**NAVY SHORE DRINKING WATER QUALITY
REPORT FOR FISCAL YEAR 2019**

February 2020

Prepared by:
Commander, Navy Installations Command
Navy Executive Agent for Drinking Water

This Page Intentionally Left Blank

EXECUTIVE SUMMARY

The Navy is committed to safeguarding the health of its personnel and their families. Ensuring safe drinking water is a top health concern. Commander, Navy Installations Command (CNIC) is the Executive Agent for drinking water quality at all Navy shore facilities and installations worldwide and serves as the single point of contact for matters related to drinking water systems.

This report is provided in accordance with OPNAVINST 5090.1E and is comprised of an inventory of all water systems, an analysis of the exceedances of health-based standards and the identification of unresolved operational and maintenance requirements.

During FY19, CNIC, working closely with its strategic partners, the Naval Facilities Engineering Command (NAVFAC), the Navy Bureau of Medicine and Surgery (BUMED) and Naval Sea Systems Command (NAVSEA) Laboratory Quality and Accreditation Office (LQAO) providing oversight and improved accountability of the Navy's drinking water program.

Across the U.S. and its territories, the Navy manages 79 drinking water systems that fall under the jurisdiction of the Environmental Protection Agency (EPA) and state laws. The Navy also manages 47 drinking water systems overseas that are not under the jurisdiction of the EPA and, for purposes of this report, are referred to as overseas drinking water (ODW) systems. These 47 ODW systems are under the primary enforcement authority of CNIC.

To maintain visibility of the Navy's commitment to ensuring the health of its personnel and families through prevention of lead in drinking water, this report highlights Navy's Lead and Copper Rule (LCR) and Lead in Priority Areas (LIPA) sampling. In FY19, Navy systems stateside and overseas continued recurring LCR sampling as required by the Safe Drinking Water Act and Department of Defense Instruction 4715.05 respectively. LIPA sampling, per OPNAVINST 5090.1E, continued at all applicable Navy systems worldwide. Per the revised Office of the Chief of Naval Operations (OPNAV) policy issued in October 2016, for each of the LCR action level exceedances in FY19, installations consulted with local preventive medicine authorities and took appropriate remedial action. Remedial actions were also executed at all installations with LIPA sample exceedances in FY19. To align with the U.S. EPA's revised *3Ts for Reducing Lead in Drinking Water in Schools and Childcare Facilities* and subsequent updated OPNAV policy, CNIC drafted CNIC Instruction 5090.6, *Navy Sampling and Testing for Lead in Drinking Water in Priority Areas*, with expected publication in FY20. CNIC Instruction 5090.6 provides updated sampling and corrective action requirements, as well as standardization of public notification letter templates.

Navy Compliance

For the 79 systems under the jurisdiction of EPA, 75 systems (95%) met all health-based standards during FY19, the rate decreasing slightly from 96% in FY18. For the 47 ODW systems, all systems (100%) met all health-based standards, an increase from 92% of systems in FY18. Where there were exceedances of standards, corrective actions were implemented and the systems returned to compliance. No exceedances required provision of alternate drinking water.

FY19 ODW Accomplishments and FY20 ODW Plan of Action and Milestones

In FY19, the Navy continued to advance the ODW program towards full compliance with U.S. water quality standards and ODW procedures and protocols. For the first time since the ODW program's inception, no health-based water quality exceedances were reported within the fiscal year. FY19 was the seventh full year of program implementation and the start of the third cycle of sanitary surveys for ODW systems. The ODW program continues to refine policies and improve processes from lessons learned in the previous cycles of implementation.

NAVSEA LQAO, as part of the Water Quality Oversight Council (WQOC) Staff, continued the third year of on-site laboratory assessments, conducting three assessments in FY19. In FY19, NAVSEA LQAO continued to provide technical assistance and track the progress of the other on-site laboratories as they implement corrective actions to achieve official NAVSEA and CNIC approval.

As part of its continuing oversight program, the WQOC completed in-depth sanitary survey evaluations for five installations, covering 10 ODW systems, to identify deficiencies in sanitary conditions, material condition, personnel training and qualifications, safety and compliance with drinking water standards and policies. In response, installations identified corrective actions and developed a Plan of Action and Milestones to address each deficiency.

In FY18, CNIC published CNIC Instruction 5090.1A, *Navy Overseas Drinking Water Program Ashore*, implementing the new ODW Program Manual (CNIC Manual 5090.1) and existing CNIC Manuals 5090.2 and 5090.3. In FY19 CNIC, in coordination with, NAVFAC and BUMED; initiated the process of consolidating the three respective manuals into one comprehensive ODW Program Manual (Draft CNIC Manual 5090.1A). When finalized, this manual will update the ODW laboratory policy and operator requirements. Final manual is expected to be out for publication in FY20. CNIC, NAVFAC and BUMED continued conducting ODW training for system operators, prospective Commanding Officers, Public Works Officers and medical professionals.

The 2020 ODW Plan of Action and Milestones builds on the 2019 accomplishments, continuing to focus on sustainable program management and providing further guidance to help resolve common sanitary survey deficiencies. Details of FY19 accomplishments and the FY20 plan are contained in the body of this report.

TABLE OF CONTENTS

| | |
|--|-----|
| Introduction..... | 1 |
| Governing Regulations | 1 |
| Figure 1. Navy Overseas Drinking Water Program Organization..... | 2 |
| Drinking Water Systems Inventory | 3 |
| Table 1. Summary of Navy Drinking Water Systems by Region..... | 4 |
| Summary of Water Quality and Exceedances | 4 |
| Navy Drinking Water Systems under EPA Jurisdiction..... | 4 |
| Navy ODW Systems..... | 5 |
| Sampling and Testing for Lead in Priority Areas | 5 |
| Lead and Copper Rule Testing | 6 |
| Sampling and Testing for Perfluoroalkyl and Polyfluoroalkyl Substances | 8 |
| Assessment, Operation and Maintenance | 8 |
| Navy Drinking Water Systems under EPA Jurisdiction..... | 8 |
| Navy ODW Systems..... | 9 |
| Figure 2. Certificate to Operate Planning Flowchart..... | 10 |
| FY19 Projects and Accomplishments..... | 11 |
| FY19 Projects..... | 11 |
| FY19 Accomplishments..... | 11 |
| FY20 Projects and Planned Actions | 13 |
| FY20 Projects..... | 13 |
| FY20 Planned Actions | 14 |
| Appendix A: Inventory of Drinking Water Systems under EPA Jurisdiction | A-1 |
| Appendix B: Inventory of Exempted Drinking Water Systems (U.S. and Territories)..... | B-1 |
| Appendix C: Inventory of Privatized Systems (U.S. and Territories) | C-1 |
| Appendix D: Inventory of ODW Systems, CTO and Operator Training Requirements | D-1 |
| Appendix E: Drinking Water Systems under EPA Jurisdiction with Exceedances..... | E-1 |

This Page Intentionally Left Blank

Introduction

The Navy is committed to safeguarding the health of its personnel and families by ensuring their drinking water is safe and meets all health-based standards. This seventh annual report identifies the compliance posture of the Navy's drinking water program and the Navy's efforts taken to deliver safe drinking water. Commander, Navy Installations Command (CNIC), supported by its strategic partners Naval Facilities Engineering Command (NAVFAC), Navy Bureau of Medicine and Surgery (BUMED) and Naval Sea Systems Command (NAVSEA), serves as the Executive Agent for drinking water quality for all Navy shore facilities and installations worldwide and maintains oversight of both U.S. and Overseas Drinking Water (ODW) systems.

Governing Regulations

In the U.S. and its territories, the Environmental Protection Agency (EPA), under the authority of the Safe Drinking Water Act (SDWA), sets health-based standards to ensure drinking water is safe for human consumption. The EPA defines human consumption as drinking, cooking, bathing, dishwashing and maintaining oral hygiene. EPA provides requirements and guidelines, adopted by most states, to implement safe drinking water program management.

Navy public drinking water systems within the U.S. and its territories are required to comply with EPA and state drinking water requirements. In the few locations where EPA is the sole regulator, Navy public drinking water systems are required to comply with EPA requirements alone.

OPNAVINST 5090.1E, *Environmental Readiness Program*, provides implementing requirements for Navy compliance with the SDWA. OPNAVINST 5090.1E incorporated the Chief of Naval Operations, Energy and Environmental Readiness Division (OPNAV N45) policy memorandum, *Navy Policy Requirements for Drinking Water Exceedances*, which requires each installation commanding officers (ICO) to consult with local preventive medicine authority (PMA) in the event of an exceedance of a drinking water maximum contaminant level, action level, health advisory or other drinking water quality standard in the U.S. and overseas.

Overseas, where the EPA does not have jurisdiction, CNIC is the primary enforcement authority for drinking water programs, setting and enforcing Navy health-based standards. Navy shore installations in foreign countries are also required to comply with health-based standards established within country-specific Department of Defense (DoD) Final Governing Standards (FGS), or in the absence of an FGS, the DoD Overseas Environmental Baseline Guidance Document (OEBGD).

As the primary enforcement authority for ODW systems, CNIC maintains an oversight structure to ensure adequate standards are in place and that ODW systems achieve and maintain compliance with standards (Figure 1). The top tier of the management and oversight structure is the Water Quality Oversight Council (WQOC). The WQOC comprises members from CNIC, NAVFAC, BUMED and NAVSEA. Director, Facilities and Environmental (CNIC N4), chairs the WQOC on behalf of the Commander. The second tier consists of the Regional Water Quality Boards (RWQB), chaired by the Region Commander (REGCOM). The third tier consists of the

Installation Water Quality Boards (IWQB), chaired by the respective Installation Commanding Officer (ICO).




Figure 1. Navy Overseas Drinking Water Program Organization

Drinking Water Systems Inventory

In FY17, NAVFAC Engineering and Expeditionary Warfare Center (EXWC) finalized a comprehensive inventory of Navy drinking water and non-potable water systems on a worldwide basis. In FY19, this inventory was reviewed for any changes to domestic and overseas sources of drinking water (Table 1). The updated FY19 inventory reflects a U.S.-regulated inventory increase of one from 78 to 79 drinking water systems to align with the Office of the Secretary of Defense (OSD) definitions of a regulated public water system (PWS). Under the OSD definitions, a regulated PWS in the U.S. must have a unique PWS identification (PWS ID) number. In FY19, two systems were added in the Mid-Atlantic Region: NWS Yorktown Pistol Range and NWS Yorktown Rifle Range, while the Barbers Point Water System in Region Hawaii was removed from the inventory to bring the total to 79 systems for FY19. Barbers Point is no longer under Navy control since it was transferred by the General Services Administration (GSA) to the Kalaeloa Water Company in November 2017. The Navy did not privatize the system, the transaction was a GSA disposal. The Navy no longer has water/wastewater systems at Barbers Point, although the Navy still remains as a customer for a small number of Navy facilities. The Navy's 79 drinking water systems under the jurisdiction of the EPA are distributed among seven Navy Regions. Appendix A provides a complete listing of these 79 drinking water systems.

The Navy's remaining domestic systems not under the direct jurisdiction of the SDWA are listed in Appendices B and C. In FY19, OSD redefined how these remaining domestic systems are categorized. The remaining systems include both consecutive water systems (water purchased from another PWS) classified as "Exempted" and privatized systems classified as "Privatized" in accordance with the new OSD definitions. While not regulated under the SDWA, "Exempted" systems are still tracked and routinely tested as required under OPNAVINST 5090.1E. "Privatized" systems' assets have been permanently turned over to a private party and are not required to comply with OPNAVINST 5090.1E and may be regulated by the EPA.

The Navy's 47 overseas systems, under the primacy of CNIC, are distributed among four Navy Regions. Appendix D provides a complete listing of the 47 ODW systems. With the removal of two systems: CFA Chinhae (Tri-Service Hangar Pohang) due to the transfer to the U.S. Marine Corps and NAS Sigonella 585 Compound with its incorporation into the NAS Sigonella NAS II system under the hauled water policy requirements, the ODW system inventory decreased from 49 in FY18 to 47 in FY19. Region Japan inventory added the existing Singapore ODW system in FY19 following the realignment of Singapore Area Coordinator under Region Japan. The ODW inventory of systems will continue to fluctuate as closures and new systems are identified. FY20 anticipates the addition of one system at NSF Redzikowo, Poland upon construction completion. Two additional overseas systems are currently being evaluated for potential inclusion in the Navy ODW program. One location in Region Southeast (CSL Comalapa) was recommended by the WQOC for possible inclusion under the program. This location is still under evaluation by Region Southeast pending Navy Marine Corps Public Health Center site visit and health assessment with anticipated resolution in FY20. The other location in Region Japan (New Sanno Hotel) was reviewed; and preliminary results indicates that it does not meet the definition of a Navy ODW system.

Table 1. Summary of Navy Drinking Water Systems by Region

| CNIC Region | Regulated PWS | Exempted | Privatized | ODW System |
|---------------------|----------------------|-----------------|-------------------|-------------------|
| CNREURAFCENT | 0 | 0 | 0 | 19 |
| CNRH | 5 | 0 | 0 | 0 |
| CNRJ | 0 | 0 | 0 | 24 |
| CNRK | 0 | 0 | 0 | 2 |
| CNRMA | 26 | 51 | 1 | 0 |
| CNRNDW | 13 | 6 | 0 | 0 |
| CNRNW | 7 | 6 | 0 | 0 |
| CNRSE | 14 | 55 | 7 | 2 |
| CNRSW | 12 | 21 | 0 | 0 |
| JRM | 2 | 0 | 0 | 0 |
| Total | 79 | 139 | 8 | 47 |

Summary of Water Quality and Exceedances

A system with any exceedance of a health-based standard, regardless of duration, is reported as being out of compliance for the entire reporting period (i.e., the FY). The FY19 EPA national average for drinking water system compliance with health-based standards was 94%, a slight increase from the FY18 EPA national average of 93%.

Navy Drinking Water Systems under EPA Jurisdiction

In FY19, 95% (75 of 79) of the Navy drinking water systems in the U.S. were compliant with health-based standards. This is a slight decrease from the 96% compliance reported in FY18, but still higher than the EPA national average of 94%. The following four Navy drinking water systems, under the jurisdiction of EPA, experienced exceedances in FY19.

- NSA Anderson: Unapproved treatment process; Use of Pool Time Chlorination Tabs
- Joint Base Anacostia Bolling (JBAB)-Anacostia: Non-detectable disinfection residual
- NAS Lemoore: Total Trihalomethane (TTHM)
- WPNSTA Earl Colts Neck (Main Base): Total Trihalomethane (TTHM)

In all cases, public notifications were issued and will be reported in the respective installations’ annual Consumer Confidence Reports (CCR), which are distributed annually, by the first of July. The CCRs are also posted to the respective region’s website and are provided to consumers. None of the exceedances required boil water notices or provision of alternate drinking water. A detailed discussion of these water system health-based exceedance and corrective action taken follows in Appendix E.

There were also two Navy exempted water systems with health-based exceedances or violations. In these instances, the water purveyor, and not the Navy, was responsible for all corrective actions and notifications, therefore they are not captured in Appendix E.

- Portsmouth Naval Shipyard (NOSC Fort Schuyler): Uncovered reservoir
- SUBASE New London (Main Base): TTHM

Navy ODW Systems

During FY19, 100% of the 47 ODW systems were compliant with health-based standards; which is an increase from the 92% compliance reported in FY18. CCRs are also distributed annually for each ODW system by July 1, 2019. The CCRs are posted to the respective region's website and are provided to consumers.

Sampling and Testing for Lead in Priority Areas

Per OPNAVINST 5090.1E, testing for lead is required for all drinking water coolers and other specified outlets in priority areas, such as schools and child development centers. On February 8, 2014, OPNAV N45 issued a policy memorandum, *Sampling and Testing for Lead in Drinking Water in Priority Areas (LIPA)*, which outlines testing requirements and clarifies policy in the now updated OPNAVINST 5090.1E. On June 6, 2017, CNIC issued technical guidance to support implementation of the OPNAV policy. In FY19, CNIC drafted CNIC Instruction 5090.6 to implement CNIC LIPA policy aligning with updated OPNAV policy and the U.S. EPA's revised 3Ts guidance. Publication is expected in FY20.

Baseline sampling was conducted and reported in the FY14 annual report. Elevated lead levels were observed at outlets in the Rota Spain DoD Education Activity (DoDEA) High School during LIPA FY14 sampling and have not been completely resolved. These deficiencies were attributed to the construction contractor's inadvertent use of lead-containing solder. The procurement policy process has been initiated with the construction contractor to address the latent defect issue. Four laboratory sinks in the school remain out of service in FY19 due to the latent defect.

In FY19, the following installations performed recurring sampling per the LIPA policy:

| | | |
|----------------|------------------|--------------------------------|
| NS Rota | NSA Bethesda | NAS Jacksonville |
| NSA Bahrain | NSF Indian Head | NB Ventura County |
| CFA Chinhae | NSWC Dahlgren | NAS Corpus Christi |
| CFA Sasebo | JRB New Orleans | NAS Patuxent River |
| NAF Atsugi | NAS Key West | NSA Mechanicsburg |
| NB Guam | NAS Kingsville | JB Anacostia-Bolling |
| NSA Anderson | NAS Pensacola | NAS Fort Worth JRB |
| NS Great Lakes | NAF El Centro | JB Pearl Harbor Hickam |
| NSA Crane | NAS Lemoore | WPNSTA Earle Colts Neck |
| NWS Yorktown | NB Point Loma | Singapore Area Coordinator |
| NS Newport | NAS Monterey | Pacific Missile Range Facility |
| NSA Annapolis | NSA Philadelphia | NAS North Island/NAB Coronado |

Of these locations, CFA Sasebo, NS Rota, NSA Bahrain, CFA Sasebo, JRB New Orleans, NAS Jacksonville, NAS Key West, NAS Corpus Christi, NAS Kingsville, and NAS Pensacola required remedial follow-up due to elevated sample results. The Rota sampling event at a new school construction identified elevated lead levels which are attributed to the use of lead solder. This new construction event triggered the second latent defect claim to be assigned to a construction contractor in Rota. Per established CNIC guidance, all sample results were shared with the school, child-care staff and parents to directly address any questions or concerns. To date no additional concerns have been raised at any of the installations with elevated sample results.

Resampling is required by LIPA policy every five years, and to avoid a surge in funding requests, it has been distributed across FY16-FY19 so that no installation exceeds the five-year standard. Due to funding priorities, NAS Whidbey Island, NAVBASE Kitsap, and NAVSTA Everett were unable to complete LIPA sampling in FY19 and plan to conduct the required sampling in FY20. Due to the operational disruption from the July 2019 earthquakes, NAWS China Lake completed their required resampling in first quarter FY20. Only sampling associated with new construction, remodeling and fixture replacement is anticipated in the out-of-cycle years. Results from recurring LIPA sampling will be summarized in annual reports and all results are posted on region or installation webpages.

Lead and Copper Rule Testing

Per the Safe Drinking Water Act, all community water systems and non-transient non-community water systems are required to perform testing under the Lead and Copper Rule (LCR). The LCR established an action level for lead and copper levels in drinking water based on the 90th percentile testing results of water samples for system-wide corrosion potential. An action level exceedance is not a violation of a health-based standard, but instead triggers other requirements such as additional monitoring, treatment techniques and public education. In 2016, the EPA released a recommended procedure for collecting lead and copper samples in response to issues observed in Flint, Michigan. EPA is also currently reviewing the LCR to determine if revisions are necessary to better protect the public from lead and copper exposures.

For overseas installations, the OEBCD and the CNIC Instructions incorporate the same language as the SDWA. In addition, the applicable FGS for any specific country may include more protective requirements of the host nation.

While it is not the intent of this report to summarize all on-going sampling occurring at Navy installations under the LCR (as exceedances of the action level are not considered health-based violations under the current definition), due to the increased visibility of lead in drinking water issues, this report includes updates on exceedances of the action levels for the Regulated PWS and ODW systems. The exceedances listed below were reported to CNIC in FY19. Each exceedance has a unique response due to the nature of the systems and populations affected. In each case, the installation consulted with their local PMA, as required by OPNAV policy and alternate water was issued if recommended.

- **CFA Chinhae (CNFK Busan HQ).** Copper exceedance previously reported in FY16 due to corrosivity of the purchased water. The installation implemented a short-term solution of installing point-of-use filters until a corrosion control system was installed and became operational in November 2017. Adjustments to the corrosion control system chemical feed eliminated the copper exceedances effective August 2018. The temporary filters were no longer required and removed in June 2019.
- **NSF Diego Garcia (Deep Draft Wharf).** The system was secured in April 2017 when test results showed levels of lead in its distribution system exceeded the action level (AL). An assessment of the distribution system in April 2018 concluded that the lead exceedance is due to the corrosive water produced from the nanofiltration plant (since it has no capability to control pH) and non-lead free backflow prevention devices and accessories in the service lines at the Bravo Wharf. Latest test results indicated levels of lead in the distribution system still exceed AL. Alternative FFHC water is being trucked to any ships and submarines at the wharf from the Nanofiltration Hauled ODW system. Backflow preventers at wharf service lines will be replaced by early next year. Additionally, a Material Evaluation Survey will be conducted on the water distribution systems to identify potential lead and copper sources. Target date to resolve lead issue is end of FY20.
- **NAB Coronado (NALF San Clemente Island System).** Because of an FY17 lead exceedance, the installation accelerated the regulatory mandated five-year lead and copper sampling schedule at high risk locations on the base and completed by 30 September 2018. Of the 81 samples taken, only nine locations required corrective actions; two were resolved and reported in the FY18 annual report. One was resolved in FY2019. The six remaining buildings should be resolved by the end of FY20.
- **NAVSTA Newport (Main Base System).** Lead exceedance reported in FY17 is still undergoing investigation. The installation has returned to a routine monitoring schedule, as required under the Lead and Copper Rule. Additionally, as a part of the corrective action plan, a corrosion control evaluation and materials survey was submitted to the local regulatory agency in June 2019. On December 31, 2019, the Navy submitted what corrective actions are planned to the regulator and we are awaiting their response. Alternate water continues to be provided at the affected locations per installation leadership.
- **COMFLEACT Yokosuka (Nagai Water System).** Lead samples collected during August 2018 exceeded the standards at one sink, but the 90th percentile action level for the water system was not exceeded. Use of the water outlet was limited to hand washing (employees were notified and a sign was posted at the sink). The water outlet was then replaced with a NSF 61 lead free certified product but high lead levels continued. Standard sampling conducted during February, April and May 2019 indicated the one outlet still exceeded the standard. The corrective action is to install a NSF 53 certified point of use filter treatment at this sink. The use of the outlet is continued to be limited to hand washing until completion of filter installation and confirmation of lead level by sampling.

Sampling and Testing for Perfluoroalkyl and Polyfluoroalkyl Substances

Per OPNAV N45 policy, *Navy Drinking Water Sampling Policy for the Perfluorochemicals (PFC) perfluorooctane sulfonate (PFOS) and perfluorooctanoic acid (PFOA)*, all required drinking water sampling for Perfluoroalkyl and Polyfluoroalkyl Substances (PFAS) was completed as outlined in the FY16 annual report. Sampling included all 80 regulated Navy water systems in the U.S., the 52 ODW systems, the 171 consecutive water systems classified as other-PWS and the 33 small systems classified as non-PWS. A comprehensive review of Navy drinking water systems conducted in FY17 revised the water system inventory numbers to 79 regulated, 185 other, and 36 non-PWS. PFAS data was collected for the systems added to the inventory, with the exception of a non-operational system in Puerto Rico. All newly identified systems, except Puerto Rico, have PFAS results below the Lifetime Health Advisory (LHA) of 70 parts per trillion (ppt), or 0.070 parts per billion (ppb).

Five water systems at three installations (NALF Fentress, NSF Diego Garcia, and NRTF Dixon) identified in the 2016 annual report had PFAS identified above the 70 ppt, or 0.070 ppb, LHA level. The FY18 annual report detailed progress at the three locations and there has been no change for FY19. NALF Fentress and NSF Diego Garcia continue to provide drinking water below the LHA and NRTF Dixon will be on alternate water indefinitely.

When new Navy drinking water systems are identified, PFAS results will be obtained to document baseline conditions in accordance with Navy policy.

Additional off-installation PFAS testing of private drinking water wells is occurring as part of the Navy's Environmental Restoration and Base Realignment and Closure (BRAC) programs. As the systems being tested are privately owned, and are not Navy drinking water systems, results are not captured in this report.

Assessment, Operation and Maintenance

Compliance monitoring gives a clear picture of the current water quality and associated impacts. However, to fully assess both current and future risks to water quality, compliance monitoring is supplemented with sanitary surveys.

Navy Drinking Water Systems under EPA Jurisdiction

The U.S. EPA and states conduct sanitary surveys of public water systems, including Navy systems, every three years for surface water systems and every five years for ground water systems. In FY19, forty-one SDWA inspections were performed by a federal or state regulator at twenty-six Navy installations, of which three were sanitary surveys at three Navy installations. Upon completion of an inspection, a report is issued to the installation noting all findings. Where deficiencies are noted that may affect water quality, immediate corrective action is initiated by the installation. At the end of FY19 only three significant deficiencies identified by the local regulator this fiscal year were still unresolved: two at NSA Crane and one at NALF San Clemente Island. A cumulative total of 57 significant deficiencies were identified as open from sanitary surveys performed since 2016 at 18 water systems located at 11 installations. The

U.S. EPA, or the state delegated primacy agency, may issue a Notice of Violation or an Administrative Order for any water quality deficiencies and did so for improper treatment chemicals at NSA Anderson in FY19 which resulted in an \$83,700 fine.

Navy ODW Systems

For ODW systems, the WQOC conducts sanitary surveys every three years, regardless of water source, to ensure high quality water systems are operating across the enterprise. Sanitary surveys can include visiting foreign water treatment plants servicing Navy installations for observation. The WQOC conducts surveys aligning with the eight EPA survey elements: water source; treatment; distribution; storage; pumps, pump facilities, controls; monitoring, sampling and reporting; management and operations; and operator training and certification. A WQOC sanitary survey report is published within 90 days of the site visit. Upon receipt, the installation prepares a plan of action and milestones (POAM) addressing each deficiency and identifies corrective actions in a real-time online tracking database, known as the ODW Requirements POAM. The Requirements POAM is reviewed by the RWQB and WQOC on a quarterly basis to ensure continuous planning, programming and execution of corrective actions. Installations and regions update the ODW Requirements POAM quarterly to report on progress of deficiency corrections. FY19 was the start of the third cycle of sanitary surveys. The third cycle benefited from lessons learned from the second cycle, including the analysis of common roadblocks to resolving significant deficiencies, ongoing development of solutions for enterprise data management, and refinement of policies to reflect program maturity.

In FY19 the WQOC conducted five sanitary surveys at the following installations: NUWC Det AUTEK, NAF Misawa-Hachinohe, NAS Sigonella, CFA Chinhae, and NSF Deveselu. A total of ten ODW systems were evaluated, identifying 277 deficiencies (of which 68 carried over from prior sanitary surveys): 79 significant, 94 moderate and 104 minor. All 277 deficiencies identified in FY19 are programmed for corrective action across the Future Years Defense Program.

A significant deficiency may be a contaminant exceedance or operational deficiency. A contaminant exceedance has the potential to affect human health, and therefore requires public notification. An operational deficiency is a defect in design, operation or maintenance; or a failure or malfunction of the source, treatment, storage or distribution system that has the potential to cause the introduction of contamination into the water. A significant operational deficiency, if left unaddressed, could cause a health-based exceedance and loss of confidence in the drinking water by the fleet, fighter and family. The most commonly identified deficiencies in WQOC sanitary surveys include water treatment, finished water storage, water system management and operations and monitoring/reporting data validation. The highest percentage of significant deficiencies documented are attributed to treatment, and management and operations. An alternate compliance process for Surface Water Treatment requirements was promulgated in FY17 to assist with the compliance demonstration of purchased water within the installation fence line. Select installations in Far East have begun pursuing alternative compliance and EURAFCENT installations are scheduled to begin surface water treatment monitoring in FY20 which will provide a path forward for compliance. In FY20, the WQOC plans to develop guidance on effective cross-connection control and backflow prevention programs and

standardize operator reporting procedures to help address common management and operation deficiencies.

The ODW program requires all ODW system operators in responsible charge (ORC) and assistant operators in responsible charge (AORC) to meet specific criteria for education qualifications, training, examination and continuing education. In FY19, ODW systems with certified operators fluctuated between 77% and 91% which is attributable to staffing turnover. Appendix D contains a listing of each ODW system and its corresponding operator training requirements.

All ODW systems are required by CNIC Instruction to obtain a Certificate to Operate (CTO). The CTO is based on the overall health and readiness of the system, which must be renewed every three years. As shown in the CTO Planning Flowchart below (Figure 2), the RWQB and WQOC evaluate the latest sanitary survey report and ODW requirements POAM progress before making recommendations for a conditional, full or no CTO. The REGCOM, upon review of all aspects of a system’s performance (e.g., training, certifications and system checks), and a recommendation from the WQOC, will issue the CTO.

In FY19, 10 conditional CTOs were reissued, bringing the total to 46 conditional CTOs and one full CTO (Singapore Area Coordinator) for the 47 ODW systems. Appendix D provides an inventory of the 47 ODW systems, actual or planned date of the sanitary survey and CTO issuance and level of operator training required.




Figure 2. Certificate to Operate Planning Flowchart (Action Holder indicated in parenthesis)

FY19 Projects and Accomplishments

FY19 Projects

The value of executed projects and other investments for FY19 was comparable to the value projected in the FY18 report. Project scopes of work include minor repairs, water line replacement and repair, water treatment plant and distribution improvements, water treatment plant generator replacement, SCADA system replacement and repairs, reverse osmosis train repair, and water tank replacement and repair.

For the 79 systems under EPA jurisdiction, 29 projects totaling \$78.2M were executed.

| | | |
|-------------|-----------------|---------|
| CNRH | 7 projects..... | \$14.3M |
| CNRMA..... | 6 projects..... | \$8.7M |
| CNRNDW..... | 7 projects..... | \$27.9M |
| CNRNW..... | 1 project..... | \$5.2M |
| CNRSW | 2 projects..... | \$6.3M |
| CJRM | 6 projects..... | \$11.5M |
| CNRSE..... | 2 projects..... | \$4.3M |

For the 47 ODW systems, the value of the executed projects and other investments for FY19 was considerably more than the \$19.2M projected in the FY18 report. Twelve projects totaling \$31.2M were executed.

| | | |
|-------------------|-----------------|---------|
| CNREURAFCENT..... | 5 projects..... | \$17.7M |
| CNRJ..... | 4 projects..... | \$5.5M |
| CNRSE..... | 3 projects..... | \$8.0M |

FY19 Accomplishments

- Completed \$109.4M of investments to drinking water infrastructure.
- CNIC published the sixth annual Navy Shore Drinking Water Quality Report.
- Installations issued all annual CCRs by July 1, 2019.
- CNIC and NAVFAC trained 73 individuals, including prospective ICOs, on their roles in Navy's drinking water program.
- NAVFAC trained 27 individuals, including operations and capital improvement personnel, on both the Safe Drinking Water Act and Overseas Drinking Water Program via online professional development training modules.
- BUMED trained 78 individuals (15 Environmental Health Officers, 60 Preventive Medicine Technicians, and 3 Civilian Environmental Specialists) on public health surveillance and responses to drinking water issues during four Preventive Medicine Drinking Water Training Courses.
- WQOC conducted quarterly ODW Stakeholders meetings, both in-person and virtual, to brief ODW progress to CNIC, NAVFAC and BUMED Flag Officer principals; and invited OPNAV N45 and N46, and DASN(E) participation.

- WQOC face-to-face workshop held 16-18 July 2019 at the Washington Navy Yard, 21 attendees participated.
- Achieved FY19 WQOC ODW Plan and Objectives
 - **Draft revised CNIC Manuals 5090.1, 5090.2, and 5090.3.** Consolidated all manuals into one ODW Program Manual, CNIC M-5090.1A, and updated ODW laboratory policy, operator requirements, and other standards since the June 2018 revision.
 - **CTO Case Studies.** Conducted case studies of two locations undergoing sanitary surveys in FY19 (CFA Chinhai and NAS Sigonella) and reviewed issues and identified roadblocks associated with attaining full CTO.
 - **ODW System Definition and Criteria.** Reviewed and revised the ODW System Definition and Inventory Criteria.
 - **BOS Contract Template.** In cooperation with FSC, reviewed and standardized the BOS contract specification template for Navy Overseas Drinking Water systems.
 - **Preventive Medicine Authority Training Courses.** Held four PMA training courses in Jacksonville, FL (22-25 January 2019), Bremerton, WA (1-5 April 2019), Naples, IT (17-21 June 2019), and Yokosuka, JA (19-21 August 2019) to continue to improve knowledge of the Navy medical role and responsibilities in the Navy's drinking water program.
 - **NAVMED P-5010-5.** Issued revised NAVMED P-5010-5, Water Supply Ashore to incorporate updates since the 2008 version.
 - **Three laboratory assessments.** NAVSEA Laboratory Quality and Accreditation Office (LQAO), on behalf of the WQOC Laboratory Authority, conducted two Phase-2 (Additional contaminant sampling and analysis) laboratory assessments at NS Guantanamo Bay and NSF Diego Garcia. NAVSEA LQAO also performed an onsite assessment of a contract laboratory for NSF Deveselu, Romania.
 - **Drinking Water Sampling Training Course.** Held a drinking water sampling course in NAVSTA Rota, Spain to improve installation drinking water sampling compliance.
 - **Chemical Certification.** Completed transition for the 11 remaining drinking water treatment chemicals to NSF/ANSI Standard 60. The initial 9 chemicals were included in the WQOC FY18 Plan and Objectives.
- WQOC Sanitary Surveys
 - Conducted five sanitary surveys of 10 ODW systems.
 - Re-issued conditional CTOs for 10 ODW systems.
- WQOC Technical Advisory Board
 - Performed engineering regulatory review of drinking water design, construction and process-change projects for meeting drinking water quality standards
 - Issued interim CTOs for the CNFK Busan drinking water system following the addition of a soda ash system for corrosion control and for the NSF Diego Garcia Main Water Treatment Plant following the addition of a raw water aerator.
 - Coordinated with EURAFCENT and U.S. Army Corps of Engineers to evaluate and provide feedback on water treatment system designs for NSF Deveselu and NSF Redzikowo.

- WQOC Laboratory Authority
 - NAVSEA LQAO, on behalf of the WQOC Laboratory Authority conducted drinking water sampling training from 3-7 June 2019 in Rota, Spain.
 - Conducted two onsite laboratory assessments at NSF Diego Garcia (April 8-12, 2019) and NS Guantanamo Bay (February 2-8, 2019) and one contract laboratory assessment for NSF Deveselu, Romania (September 18-20, 2019).
 - Continued to provide technical assistance to NS Guantanamo Bay and NSF Diego Garcia to resolve findings identified during onsite laboratory assessments.
 - Continued coordination with U.S. Army Public Health Command to resolve drinking water sampling compliance challenges in EURAFCENT.
 - Reviewed and validated third-party accredited laboratories as requested.
- WQOC Navy Operator Certification Authority Board
 - Held Annual NOCA Board Face to Face Workshop from August 5-8, 2019 at NAVFAC Southeast.
 - Administered Navy operator certification exams to 58 potential drinking water operators.
 - Recommended 65 drinking water operators for Navy certification.

FY20 Projects and Planned Actions

FY20 Projects

For the projected 79 systems under EPA jurisdiction, 29 projects totaling \$123.8M are planned for execution. Project scopes of work include minor repairs, water line replacement and repair, water treatment plant and distribution improvements, backflow prevention repairs, pump station repairs, water meter installation, well repair water system security upgrades, reverse osmosis train repair, and water tank repair. These projects will help address existing deficiencies and reduce exceedances.

| | | |
|-------------|-----------------|---------|
| CNRH | 9 projects..... | \$40.8M |
| CNRMA..... | 4 projects..... | \$11.1M |
| CNRNDW..... | 2 projects..... | \$25.4M |
| CNRNW..... | 2 projects..... | \$0.6M |
| CNRSW | 3 projects..... | \$28.8M |
| CJRM | 9 projects..... | \$16.0M |
| CNRSE..... | 2 projects..... | \$1.1M |

For the projected 47 ODW systems, the value of planned projects and other investments for FY20 is considerably more than the \$19.2M projected in the FY19 report. Fourteen projects totaling \$36.3M are planned for execution.

| | | |
|-------------------|-----------------|---------|
| CNREURAFCENT..... | 3 projects..... | \$17.7M |
| CNRJ..... | 6 projects..... | \$1.0M |
| CNRSE..... | 5 projects..... | \$17.6M |

FY20 Planned Actions

Building on the previous year's accomplishments, the ODW program continues its momentum towards program sustainability. The program will continue to increase program management capacity to establish sustainment, with a focus on training and outreach to the regions and installations. The WQOC will progressively and incrementally accomplish goals and objectives. The following are discrete objectives for FY20:

- **PMA Drinking Water Training Course.** Organize and hold five Preventive Medicine Authority (PMA) Drinking Water Training Courses.
- **PMA Drinking Water Course Modules.** Revise Preventive Medicine Authority (PMA) Drinking Water Course modules and lesson training guides.
- **Laboratory Visits.** Conduct three laboratory visits. Two under routine biennial assessments, and one moving through Phase 2 for additional contaminant sampling and analysis.
- **Effective Cross-Connection Control and Backflow Prevention.** Provide guidance to region and installation water quality boards on "effective" cross-connection control and backflow prevention programs.
- **Standardize Operator Reporting Procedures.** Review and revise standard operating procedures for overseas drinking water operator reporting requirements.
- **Regional Outreach Workshops.** Hold three regional face-to-face workshops to foster collaboration and communication between headquarters and region/installation staff and expand scope and workshop audience to- include Facilities and Housing representatives. Workshops to be held in Jacksonville, Florida (February 19-20, 2020), Naples, Italy (March 17-19, 2020), and Yokosuka, Japan (April 21-23, 2020).
- **Database Improvements.** Implement database improvements to the ODW Requirements POAM; incorporating new data management functionality and visualization.
- **Sanitary Survey Request for Information.** Provide an organized, easily managed, online folder structure for sanitary survey request for information (RFI) data; provide training and assistance to installations; check files periodically.

Appendix A: Inventory of Drinking Water Systems under EPA Jurisdiction

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type¹</i> | <i>Population Served</i> |
|--|--|---|--------------------------|
| NAVY REGION HAWAII | | | |
| JOINT BASE PEARL HARBOR-HICKAM HI | Camp Stover Water System | Consecutive | 595 |
| JOINT BASE PEARL HARBOR-HICKAM HI | NAVMAG PH (Lualualei) Water System | Primary Groundwater | 114 |
| JOINT BASE PEARL HARBOR-HICKAM HI | NCTAMS PACIFIC Water System | Primary Groundwater | 6,470 |
| JOINT BASE PEARL HARBOR-HICKAM HI | Joint Base Pearl Harbor Hickam Water System | Primary Groundwater | 65,230 |
| PACIFIC MISSILE RANGE FACILITY BARKING SANDS HI | Pacific Missile Range Facility Barking Sands Water System | Primary Groundwater | 1,200 |
| NAVY REGION MID-ATLANTIC | | | |
| ABL ROCKET CENTER WV | NIROP Allegany Ballistics Laboratory | Groundwater Under Direct Influence of Surface Water | 1,600 |
| JEB LITTLE CREEK-FORT STORY VA | JEB Little Creek Fort Story VA (Little Creek) | Consecutive | 9,782 |
| NAS OCEANA VA | Dam Neck | Consecutive | 3,000 |
| NAS OCEANA VA | NAS Oceana Fentress VA (OLF Fentress) | Primary Groundwater | 40 |
| NAS OCEANA VA | NAS Oceana (COMNAV MIDLANT) | Consecutive | 7,900 |
| NAVSTA GREAT LAKES IL | NTC Great Lakes IL NAVSTA Great Lakes | Primary Surface Water | 21,253 |
| NAVSTA NEWPORT RI | NAVSTA Newport – RI (Fort Adams) | Consecutive | 319 |
| NAVSTA NEWPORT RI | NAVSTA Newport – RI (Main Base) | Consecutive | 7,871 |
| NAVSTA NORFOLK VA | DFSC Craney Island | Consecutive | 100 |
| NAVSTA NORFOLK VA | Naval Station Norfolk | Consecutive | 48,300 |
| NSS NORFOLK NAVAL SHIPYARD VA | NSA Norfolk Naval Shipyard | Consecutive | 17,000 |
| NSS NORFOLK NAVAL SHIPYARD VA | St. Juliens Creek Annex Drinking Water (East and West) | Consecutive | 1,500 |
| NSA CRANE IN | NSA Crane | Primary Surface Water | 5,543 |
| NSA HAMPTON ROADS VA | NMC Portsmouth (NSA Hampton Roads) VA Consecutive Water System | Consecutive | 6,350 |
| NSA HAMPTON ROADS VA | NSA Northwest (NSA Northwest Annex) | Primary Groundwater | 2,397 |
| NSY BOS PORTSMOUTH NH | NSY Portsmouth ME (Great Pond Cabins 1-5) | Primary Groundwater | 30 |
| NSY BOS PORTSMOUTH NH | NSY Portsmouth NH (Great Pond Campground) | Primary Groundwater | 36 |
| NSY BOS PORTSMOUTH NH | NSY Portsmouth ME (Great Pond REC Hall) | Primary Groundwater | 25 |

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type¹</i> | <i>Population Served</i> |
|----------------------------------|---|--------------------------------|--------------------------|
| NSY BOS PORTSMOUTH NH | NSY Portsmouth ME Rangely Multipurpose (wells #1 and #2) | Primary Groundwater | 33 |
| NSY BOS PORTSMOUTH NH | NSY Portsmouth ME Rangely Training Lab | Primary Groundwater | 33 |
| WPNSTA EARLE COLTS NECK NJ | WPNSTA EARLE COLTS NECK – MSC Fire School | Primary Groundwater | 25 |
| WPNSTA EARLE COLTS NECK NJ | WPNSTA EARLE COLTS NECK – NJ Consecutive System Main Base | Consecutive | 1,200 |
| WPNSTA YORKTOWN VA | COMNAVREG MIDLANT (NWS Yorktown) | Consecutive | 2,100 |
| WPNSTA YORKTOWN VA | Cheatham Annex Water System | Consecutive | 800 |
| WPNSTA YORKTOWN VA | NWS Yorktown Pistol Range | Groundwater | 50 |
| WPNSTA YORKTOWN VA | NWS Yorktown Rifle Range | Groundwater | 98 |
| NAVAL DISTRICT WASHINGTON | | | |
| JB ANACOSTIA-BOLLING DC | JBAB - Anacostia | Consecutive | 16,559 |
| NAS PATUXENT RIVER MD | NAS Patuxent River | Groundwater | 23,000 |
| NAS PATUXENT RIVER MD | NAS Patuxent River, Solomons | Groundwater | 600 |
| NAS PATUXENT RIVER MD | NAS Patuxent River, Webster Field | Groundwater | 1,200 |
| NSA ANNAPOLIS MD | NRL Chesapeake Beach Detachment | Primary Groundwater | 60 |
| NSA ANNAPOLIS MD | USNA Annapolis (NSA Annapolis) | Primary Groundwater | 8,700 |
| NSA SOUTH POTOMAC MD | NSF Indian Head (NSA South Potomac) | Primary Groundwater | 3,321 |
| NSA SOUTH POTOMAC MD | NSF Indian Head (NSA South Potomac) Stump Neck Annex | Primary Groundwater | 495 |
| NSA SOUTH POTOMAC MD | NSWC Dahlgren Mainside (NSA South Potomac) | Primary Groundwater | 11,224 |
| NSA SOUTH POTOMAC MD | NSWC Dahlgren Pumpkin Neck (NSA South Potomac) | Primary Groundwater | 25 |
| NSA WASHINGTON DC | NSA Washington – Washington Navy Yard | Consecutive | 15,700 |
| NSA WASHINGTON DC | NRL – Blossom Point | Primary Groundwater | 125 |
| NSA WASHINGTON DC | U.S. Naval Observatory | Consecutive | 250 |
| NAVY REGION NORTHWEST | | | |
| NAS WHIDBEY ISLAND WA | Naval Air Station/Whidbey Island | Consecutive | 13,867 |
| NAVBASE KITSAP BREMERTON WA | Jackson Park Naval Hospital | Consecutive | 2,277 |
| NAVBASE KITSAP BREMERTON WA | Naval Base Kitsap at Bangor | Primary Groundwater | 16,828 |
| NAVBASE KITSAP BREMERTON WA | Naval Base Kitsap at Bremerton | Consecutive | 12,078 |
| NAVBASE KITSAP BREMERTON WA | Naval Base Kitsap at Keyport | Primary Groundwater | 1,540 |
| NAVMAG INDIAN ISLAND | Naval Magazine Indian Island | Consecutive | 180 |

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type¹</i> | <i>Population Served</i> |
|------------------------------|--|--------------------------------|--------------------------|
| NAVSTA EVERETT WA | US Naval Radio Station (T) Jim Creek | Primary Groundwater | 200 |
| NAVY REGION SOUTHEAST | | | |
| NAS CORPUS CHRISTI TX | NAS Corpus Christi | Consecutive | 8,656 |
| NAS JACKSONVILLE FL | NAS Jacksonville Water System | Primary Groundwater | 22,000 |
| NAS JRB FORT WORTH TX | NAS JRB Fort Worth Water System | Consecutive | 9,000 |
| NAS KINGSVILLE TX | NAS Kingsville | Consecutive | 1,520 |
| NAS KINGSVILLE TX | NALF Orange Grove | Primary Groundwater | 36 |
| NAS MERIDIAN MS | NAS Meridian | Primary Groundwater | 2,800 |
| NAS PENSACOLA FL | Pensacola - NTTCC Corry/NAS Pensacola | Primary Groundwater | 22,600 |
| NAS PENSACOLA FL | Saufley Field | Consecutive | 1,728 |
| NAS WHITING FIELD FL | NAS Whiting Field | Primary Groundwater | 3,094 |
| NAS WHITING FIELD FL | NOLF Choctaw | Primary Groundwater | 25 |
| NAVSTA MAYPORT FL | Mayport Water System | Primary Groundwater | 20,500 |
| NCBC GULFPORT MS | NCBC Gulfport Water System | Primary Groundwater | 3,553 |
| NSA MID-SOUTH TN | NSA Mid-South | Primary Groundwater | 6,300 |
| SUBASE KINGS BAY GA | SUBASE Kings Bay | Primary Groundwater | 9,730 |
| NAVY REGION SOUTHWEST | | | |
| NAVBASE CORONADO CA | NALF San Clemente Island | Consecutive | 670 |
| NAVBASE CORONADO CA | NAS North Island and NAB Coronado | Consecutive | 36,000 |
| NAVBASE CORONADO CA | SERE Camp (Warner Springs RTS) | Primary Groundwater | 52 |
| NAF EL CENTRO CA | NAF El Centro | Primary Surface Water | 2,063 |
| NAS FALLON NV | NAS Fallon | Primary Groundwater | 3,000 |
| NAS FALLON NV | NAS Fallon Centroid | Primary Groundwater | 80 |
| NAS LEMOORE CA | NAS Lemoore | Primary Surface Water | 12,000 |
| NAVBASE VENTURA CA | NAS Point Mugu (NAVBASE Ventura CO) | Consecutive | 5,700 |
| NAVBASE VENTURA CA | NCBC Port Hueneme (NAVBASE Ventura CO) | Consecutive | 11,500 |
| NAVBASE VENTURA CA | San Nicolas Island | Primary Surface Water | 187 |
| NAWS CHINA LAKE CA | NAWS China Lake Water System (North Range FKA Harvey Field Area) | Primary Groundwater | 5,000 |
| NAWS CHINA LAKE CA | South Range (NAWS China Lake FKA Randsburg Wash Area) | Primary Groundwater | 150 |

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type</i> ¹ | <i>Population Served</i> |
|------------------------------|-------------------------|---------------------------------|--------------------------|
| JOINT REGION MARIANAS | | | |
| NAVBASE GUAM GU | Navy Water System, Guam | Primary Surface Water | 12,500 |
| NSA ANDERSEN GU | Andersen Water System | Primary Groundwater | 7,700 |

1 SOURCE TYPE DEFINITIONS

Groundwater: Groundwater wells isolated from surface water sources

Surface Water: Rivers, lakes, streams

Groundwater Under Direct Influence: Shallow groundwater wells connected with surface water sources

Primary: Navy produced water

Consecutive: Navy purchased water

Appendix B: Inventory of Exempted Drinking Water Systems (U.S. and Territories)

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type¹</i> | <i>Population Served²</i> |
|--|--|--------------------------------|--------------------------------------|
| NAVY REGION MID-ATLANTIC | | | |
| JOINT EXPEDITIONARY BASE LITTLE CREEK FORT STORY VA | JEBLCFS Housing South of Shore Drive (Wellings Ct, Sandpiper Crescent, Port Lyautey) | Consecutive | 1,380 |
| JOINT EXPEDITIONARY BASE LITTLE CREEK FORT STORY VA | JEBLCFS Atlantic Beach | Consecutive | 120 |
| NAS OCEANA VA | Midway Manor | Consecutive | 1,480 |
| NAS OCEANA VA | NEXCOM Headquarters | Consecutive | 850 |
| NAS OCEANA VA | NOSC Baltimore MD | Consecutive | 950 |
| NAS OCEANA VA | NOSC Greensboro NC | Consecutive | 50 |
| NAS OCEANA VA | NOSC MCRC Charlotte NC | Consecutive | 50 |
| NAS OCEANA VA | NOSC Raleigh NC | Consecutive | 50 |
| NAS OCEANA VA | NOSC Richmond VA | Consecutive | 50 |
| NAS OCEANA VA | NOSC Roanoke VA | Consecutive | 50 |
| NAS OCEANA VA | Oceana Booth Moore | Consecutive | 500 |
| NAVSTA GREAT LAKES IL | Akron Canton AFRC | Consecutive | 345 |
| NAVSTA GREAT LAKES IL | Ft Sheridan PPV Housing Area | Consecutive | 886 |
| NAVSTA GREAT LAKES IL | Glenview PPV Housing Area | Consecutive | 364 |
| NAVSTA GREAT LAKES IL | NOSC Cincinnati | Consecutive | 234 |
| NAVSTA GREAT LAKES IL | NOSC Columbus OH | Consecutive | 576 |
| NAVSTA GREAT LAKES IL | NOSC Decatur IL | Consecutive | 99 |
| NAVSTA GREAT LAKES IL | NOSC Green Bay WI | Consecutive | 134 |
| NAVSTA GREAT LAKES IL | NOSC Louisville KY | Consecutive | 286 |
| NAVSTA GREAT LAKES IL | NOSC Milwaukee | Consecutive | 148 |
| NAVSTA GREAT LAKES IL | NOSC Peoria IL | Consecutive | 85 |
| NAVSTA GREAT LAKES IL | NOSC Saginaw MI | Consecutive | 103 |
| NAVY MEDICINE EAST | TRICARE Outpatient Clinic Chesapeake, VA | Consecutive | 25 |
| NAVY MEDICINE EAST | TRICARE Outpatient Clinic Virginia Beach, VA | Consecutive | 25 |

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type¹</i> | <i>Population Served²</i> |
|------------------------------|--|--------------------------------|--------------------------------------|
| NORFOLK NAVAL SHIPYARD VA | NNSY New Gosport | Consecutive | 25 |
| NORFOLK NAVAL SHIPYARD VA | Stanley Ct | Consecutive | 279 |
| NSA MECHANICSBURG PA | Naval Support Activity, Mechanicsburg | Consecutive | 4,200 |
| NSA MECHANICSBURG PA | Naval Support Activity Philadelphia | Consecutive | 6,000 |
| NSA MECHANICSBURG PA | Philadelphia Navy Yard Annex | Consecutive | 3,000 |
| NSA MECHANICSBURG PA | NOSC Avoca PA | Consecutive | 25 |
| NSA MECHANICSBURG PA | NOSC Ebensburg | Consecutive | 25 |
| NSA MECHANICSBURG PA | NOSC Erie PA | Consecutive | 25 |
| NSA MECHANICSBURG PA | NOSC Lehigh Valley PA | Consecutive | 25 |
| PORTSMOUTH NAVAL SHIPYARD NH | NOSC Buffalo NY | Consecutive | 72 |
| PORTSMOUTH NAVAL SHIPYARD NH | NOSC Fort Schuyler NY | Consecutive | 85 |
| PORTSMOUTH NAVAL SHIPYARD NH | NOSC Plainville CT | Consecutive | 51 |
| PORTSMOUTH NAVAL SHIPYARD NH | NOSC Quincy MA | Consecutive | 92 |
| PORTSMOUTH NAVAL SHIPYARD NH | NOSC Schenectady | Consecutive | 70 |
| PORTSMOUTH NAVAL SHIPYARD NH | NOSC Syracuse NY | Consecutive | 33 |
| PORTSMOUTH NAVAL SHIPYARD NH | NSY Portsmouth ME (Main Base) | Consecutive | 6,000 |
| PORTSMOUTH NAVAL SHIPYARD NH | USS Constitution | Consecutive | 25 |
| SUBASE NEW LONDON CT | Mitchel Field NY | Consecutive | 30 |
| SUBASE NEW LONDON CT | Mitchel Manor 1 NY | Consecutive | 500 |
| SUBASE NEW LONDON CT | Saratoga Springs | Consecutive | 35 |
| SUBASE NEW LONDON CT | SUBASE NEW LONDON - CT Conning Towers Housing | Consecutive | 1,000 |
| SUBASE NEW LONDON CT | SUBASE NEW LONDON - CT Nautilus Park 1, 2, and 3 South Housing | Consecutive | 3,700 |
| SUBASE NEW LONDON CT | SUBASE NEW LONDON - CT Polaris Park Housing | Consecutive | 300 |
| SUBASE NEW LONDON CT | SUBASENLON Main Base | Consecutive | 9,800 |
| SUBASE NEW LONDON CT | SUBASENLON Trident Park Housing | Consecutive | 1,100 |
| WPNSTA EARLE COLTS NECK NJ | WPNSTA Earle Colts Neck - NJ Waterfront - Admin Area | Consecutive | 47 |
| WPNSTA EARLE COLTS NECK NJ | WPNSTA Earle Colts Neck - NJ Waterfront - Industrial Area | Consecutive | 80 |

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type¹</i> | <i>Population Served²</i> |
|----------------------------------|---|--------------------------------|--------------------------------------|
| NAVAL DISTRICT WASHINGTON | | | |
| NSA ANNAPOLIS MD | NSA Annapolis North Severn Water System | Consecutive | 2,600 |
| NSA BETHESDA MD | NSA Bethesda | Consecutive | 12,056 |
| NSA WASHINGTON DC | Arlington Service Center | Consecutive | 250 |
| NSA WASHINGTON DC | Naval Maritime Intelligence Center | Consecutive | 25 |
| NSA WASHINGTON DC | NSWCCD Carderock Site | Consecutive | 2,184 |
| NSA WASHINGTON DC | Washington DC – NRL Main Site Water System | Consecutive | 4,144 |
| NAVY REGION NORTHWEST | | | |
| NAVAL BASE KITSAP - BANGOR WA | Manchester WA | Consecutive | 37 |
| NAVAL STATION EVERETT WA | Bayview ID | Consecutive | 94 |
| NAVAL STATION EVERETT WA | NAVSTA Everett | Consecutive | 4,000 |
| NAVAL STATION EVERETT WA | NOSC Minneapolis | Consecutive | 65 |
| NAVAL STATION EVERETT WA | Pacific Beach | Consecutive | 35 |
| NAVAL STATION EVERETT WA | Smokey Point (Family Service Center) Marysville | Consecutive | 500 |
| NAVY REGION SOUTHEAST | | | |
| CBC GULFPORT MS | Lakeside Housing | Consecutive | 300 |
| CBC GULFPORT MS | Woolmarket (De Soto) | Consecutive | 100 |
| NAS CORPUS CHRISTI TX | NOSC Harlingen | Consecutive | 149 |
| NAS CORPUS CHRISTI TX | NOSC Houston | Consecutive | 1,052 |
| NAS CORPUS CHRISTI TX | NOSC San Antonio | Consecutive | 710 |
| NAS CORPUS CHRISTI TX | Peary Place Trans Site | Consecutive | 25 |
| NAS JACKSONVILLE FL | DLA – DRMS | Consecutive | 25 |
| NAS JRB FORT WORTH TX | NOSC Amarillo | Consecutive | 97 |
| NAS JRB FORT WORTH TX | NOSC Austin | Consecutive | 269 |
| NAS JRB FORT WORTH TX | NOSC El Paso | Consecutive | 269 |
| NAS JRB FORT WORTH TX | NOSC Oklahoma City OK | Consecutive | 319 |
| NAS JRB FORT WORTH TX | NOSC Tulsa | Consecutive | 182 |
| NAS JRB FORT WORTH TX | NOSC Waco | Consecutive | 102 |

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type¹</i> | <i>Population Served²</i> |
|--------------------------|---|--------------------------------|--------------------------------------|
| NAS JRB FORT WORTH TX | NOSC Wichita | Consecutive | 119 |
| NAS PENSACOLA | Blue Angels Recreation Area (Bronson Field) | Consecutive | 50 |
| NAS JRB NEW ORLEANS LA | NOSC MCRC Shreveport | Consecutive | 200 |
| NAS JRB NEW ORLEANS LA | SPAWAR New Orleans, LA | Consecutive | 300 |
| NAS JRB NEW ORLEANS LA | NAS JRB New Orleans Plaquemines Parish Govt | Consecutive | 9,500 |
| NAS KEY WEST FL | NOSC Miami FL | Consecutive | 40 |
| NAS KEY WEST FL | NOSC W Palm Beach | Consecutive | 40 |
| NAS KEY WEST FL | NUWC Autec | Consecutive | 155 |
| NAS KEY WEST FL | Fleming Key Magazine | Consecutive | 54 |
| NAS MERIDIAN MS | OLF Bravo | Consecutive | 25 |
| NAVSTA MAYPORT FL | Commissary Site Mayport | Consecutive | 500 |
| NAVSTA MAYPORT FL | MAYPORT FISC Jacksonville (Fuel Depot) | Consecutive | 25 |
| NAVSTA MAYPORT FL | Mayport Off-Base Housing | Consecutive | 2,000 |
| NAVSUPACT MID-SOUTH TN | NOSC Chattanooga | Consecutive | 310 |
| NAVSUPACT MID-SOUTH TN | NOSC Kansas City MO | Consecutive | 307 |
| NAVSUPACT MID-SOUTH TN | NOSC Knoxville | Consecutive | 374 |
| NAVSUPACT MID-SOUTH TN | NOSC Little Rock | Consecutive | 161 |
| NAVSUPACT MID-SOUTH TN | NOSC Nashville (Smyrna) | Consecutive | 285 |
| NAVSUPACT MID-SOUTH TN | NOSC Springfield | Consecutive | 201 |
| NAVSUPACT MID-SOUTH TN | NOSC St. Louis | Consecutive | 201 |
| NAVSUPACT MID-SOUTH TN | Weldon Spring Training Area | Consecutive | 125 |
| NAVSUPACT PANAMA CITY FL | NOSC NMRC Tallahassee | Consecutive | 118 |
| NAVSUPACT PANAMA CITY FL | NSA Panama City - Consecutive System | Consecutive | 4,305 |
| NAWCTSD ORLANDO FL | NOSC Orlando FL | Consecutive | 95 |
| NAWCTSD ORLANDO FL | NOSC Tampa FL | Consecutive | 180 |
| NAWCTSD ORLANDO FL | NSA Orlando | Consecutive | 1,300 |
| SUBASE KINGS BAY GA | Lake Allatoona Area | Consecutive | 40 |
| SUBASE KINGS BAY GA | NOSC – MCRC Atlanta | Consecutive | 244 |

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type¹</i> | <i>Population Served²</i> |
|---|---|--------------------------------|--------------------------------------|
| NAS WHITING FIELD | NOLF Brewton | Consecutive | 25 |
| NAS WHITING FIELD | NOLF Evergreen | Consecutive | 25 |
| NAS WHITING FIELD | NOLF Harold | Consecutive | 25 |
| NAS WHITING FIELD | NOLF Holley | Consecutive | 25 |
| NAS WHITING FIELD | NOLF Pace | Consecutive | 25 |
| NAS WHITING FIELD | NOLF Santa Rosa | Consecutive | 25 |
| NAS WHITING FIELD | NOLF Silverhill | Consecutive | 25 |
| NAS WHITING FIELD | NOLF Site 8 | Consecutive | 25 |
| NAS WHITING FIELD | NOLF Spencer | Consecutive | 25 |
| NAS WHITING FIELD | NOLF Wolf | Consecutive | 25 |
| NAS WHITING FIELD | OLF Barin | Consecutive | 25 |
| NAS WHITING FIELD | Whiting Park | Consecutive | 25 |
| NAS WHITING FIELD | Whiting Pines | Consecutive | 25 |
| SPACE AND NAVAL WARFARE SYSTEMS CENTER SC | SPAWARSYSCEM Atlantic: North Charleston, SC | Consecutive | 1,750 |
| NAVY REGION SOUTHWEST | | | |
| NAS FALLON NV | NOSC Reno | Consecutive | 125 |
| NAS LEMOORE CA | NOSC Alameda | Consecutive | 227 |
| NAS LEMOORE CA | NOSC Sacramento | Consecutive | 117 |
| NAS LEMOORE CA | NOSC San Jose | Consecutive | 87 |
| NAVSUPPACT MONTEREY | Navy School Annex | Consecutive | 400 |
| NAVSUPPACT MONTEREY | NSA Monterey | Consecutive | 3,100 |
| NAVBASE CORONADO CA | Imperial Beach OLF | Consecutive | 1,415 |
| NAVBASE POINT LOMA CA | Balboa Ave | Consecutive | 50 |
| NAVBASE POINT LOMA CA | Lindberg Field | Consecutive | 200 |
| NAVBASE POINT LOMA CA | SUBASE San Diego (NAVBASE Point Loma) | Consecutive | 14,000 |
| NAVBASE SAN DIEGO CA | 1220 Pacific Hwy | Consecutive | 513 |
| NAVBASE SAN DIEGO CA | Balboa Hospital | Consecutive | 2,981 |
| NAVBASE SAN DIEGO CA | Bayview Hills Housing | Consecutive | 2,203 |

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type</i> ¹ | <i>Population Served</i> ² |
|--------------------------|---------------------------------------|---------------------------------|---------------------------------------|
| NAVBASE SAN DIEGO CA | Broadway complex | Consecutive | 1,400 |
| NAVBASE SAN DIEGO CA | Mission Gorge Rec Area | Consecutive | 98 |
| NAVBASE SAN DIEGO CA | NAVBASE San Diego | Consecutive | 50,000 |
| NAVWPNSTA SEAL BEACH CA | NOSC Moreno | Consecutive | 112 |
| NAVWPNSTA SEAL BEACH CA | NWPNSTA Seal Beach – CA | Consecutive | 167 |
| NAVWPNSTA SEAL BEACH CA | NWPNSTA Seal Beach Der Norco – CA | Consecutive | 1,305 |
| NAVWPNSTA SEAL BEACH CA | NWPNSTA Seal Beach Det Fallbrook – CA | Consecutive | 350 |
| NAVWPNSTA SEAL BEACH CA | San Pedro Fuel Depot | Consecutive | 50 |

1 SOURCE TYPE DEFINITIONS. All exempted drinking water systems are consecutive systems. Consecutive systems are those where water is purchased from a regulated PWS and distributed through the installation.

Appendix C: Inventory of Privatized Systems (U.S. and Territories)

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type¹</i> | <i>Population Served²</i> |
|---------------------------------|---------------------------------------|--------------------------------|--------------------------------------|
| NAVY REGION MID-ATLANTIC | | | |
| JEB LITTLE CREEK-FORT STORY VA | Fort Story | Consecutive | 2,642 |
| NAVY REGION SOUTHEAST | | | |
| NAS KEY WEST | Dredgers Key - Sigsbee | Consecutive | 71 |
| NAS KEY WEST | NAS Key West | Consecutive | 3,500 |
| NAS KEY WEST | Truman Annex | Consecutive | 84 |
| NAS KEY WEST | Trumbo Point Annex | Consecutive | 37 |
| NAS KEY WEST | BRMCL (Branch Health Clinic Key West) | Consecutive | 83 |
| NAS KEY WEST | NRTF Saddlebunch | Consecutive | 2 |
| NSF BEAUFORT | NH Beaufort SC | Consecutive | 200 |

This Page Intentionally Left Blank

Appendix D: Inventory of ODW Systems, CTO and Operator Training Requirements

| Installation Name | Water System | Source Type ¹ | Population Served | CTO Actual / Planned Dates | | Operator Training Requirement ³ |
|--|---------------------------------|--------------------------|-------------------|---|---------------------------------|--|
| | | | | Most Recent Cert. to Operate ² | WQOC Sanitary Survey Site Visit | |
| NAVY REGION EUROPE, AFRICA, CENTRAL | | | | | | |
| NSA NAPLES ITALY | NSA Naples Capodichino | Consecutive | 3,000 | Jan-18 | Jul-20 | T3, D2 |
| NSA NAPLES ITALY | NSA Naples Support Site | Consecutive | 4,000 | Jan-18 | Jul-20 | D1 |
| NSA NAPLES ITALY | NSA Naples Olde Mill Inn Gaeta | Consecutive | 200 | Jan-18 | Jul-20 | T1, D1 |
| NSA NAPLES ITALY | NSA Naples Carney Park | Consecutive | 200 | Jan-18 | Jul-20 | T1, D1 |
| NSA NAPLES ITALY | NAS Naples Lago Patria SATCOM | Consecutive | 45 | Jan-18 | Jul-20 | T1, D1 |
| NAVSTA ROTA SPAIN | NAVSTA ROTA | Consecutive | 12,141 | Dec-18 | FY21 | T1, D3 |
| NAS SIGONELLA ITALY | NAS Sigonella - NAS I | Groundwater | 900 | Oct-16 | May-19 | T3, D1 |
| NAS SIGONELLA ITALY | NAS Sigonella - NAS II | Groundwater | 2,600 | Oct-16 | May-19 | T3, D1 |
| NAS SIGONELLA ITALY | NAS Sigonella - Marinai Housing | Groundwater | 1,500 | Oct-16 | May-19 | T3, D1 |
| NAS SIGONELLA ITALY | NAS Sigonella - NRTF Niscemi | Consecutive | 35 | Oct-16 | May-19 | D1 |
| NSA SOUDA BAY GREECE | NSA Souda Bay | Consecutive | 1,300 | Apr-18 | May-20 | T1, D1 |
| NSA BAHRAIN BAHRAIN | NSA – Bahrain (NSA I) | Consecutive | 4,000 | Mar-19 | FY21 | T3, D2 |
| NSA BAHRAIN BAHRAIN | NSA – Bahrain (NSA II) | Consecutive | 2,000 | Mar-19 | FY21 | T3, D1 |
| NSA BAHRAIN BAHRAIN | NSA – Bahrain (BANZ) | Consecutive | 400 | Mar-19 | FY21 | D1 |
| NSA BAHRAIN BAHRAIN | NSA – Bahrain (AV Unit) | Consecutive | 300 | Mar-19 | FY21 | D1 |
| SHAIKH ISA AIR BASE (NSA BAHRAIN) BAHRAIN | ISA Air Base | Consecutive | 2,200 | Mar-19 | FY21 | T3, D3 |
| CAMP LEMONIER DJIBOUTI | Camp Lemonier, Djibouti | Groundwater | 5,300 | Apr-18 | Mar-20 | T3, D2 |
| NSF DEVESELU, ROMANIA | Deveselu, Activation Camp | Groundwater | 50 | May-17 | Sep-19 | T1, D1 |
| NSF DEVESELU, ROMANIA | Deveselu, Main Site | Groundwater | 250 | May-17 | Sep-19 | T1, D1 |
| NAVY REGION KOREA | | | | | | |
| CFA CHINHAЕ KOREA | COMFLEACT Chinhae | Groundwater | 414 | Jun-17 | Jun-19 | T2, D2 |
| CFA CHINHAЕ KOREA | CNFK HQ Busan | Consecutive | 80 | Nov-16 | Jun-19 | T1, D1 |

| Installation Name | Water System | Source Type ¹ | Population Served | CTO Actual / Planned Dates | | Operator Training Requirement ³ |
|--|---------------------------------------|------------------------------------|-------------------|---|---------------------------------|--|
| | | | | Most Recent Cert. to Operate ² | WQOC Sanitary Survey Site Visit | |
| NAVY REGION JAPAN | | | | | | |
| NSF DIEGO GARCIA BRITISH INDIAN OCEAN TERRITORY (BIOT) | Main Water System | Groundwater Under Direct Influence | 3,000 | Feb-18 | Jun-20 | T3, D3 |
| NSF DIEGO GARCIA BIOT | Nanofiltration Hauled Water | Groundwater Under Direct Influence | 3,000 | Feb-18 | Jun-20 | T3, D2 |
| NSF DIEGO GARCIA BIOT | Deep Draft Wharf | Groundwater Under Direct Influence | 100 | Feb-18 | Jun-20 | T3, D1 |
| CFA YOKOSUKA JAPAN | Fleet Mail Center Water System | Consecutive | 18 | Oct-17 | Apr-20 | D1 |
| CFA YOKOSUKA JAPAN | Azuma/Hakozaki Fuel Terminal | Consecutive | 180 | Oct-17 | Apr-20 | D1 |
| CFA YOKOSUKA JAPAN | Ikego Housing | Consecutive | 3,100 | Oct-17 | Apr-20 | T1, D1 |
| CFA YOKOSUKA JAPAN | Nagai Communication Facility | Consecutive | 1 | Oct-17 | Apr-20 | D1 |
| CFA YOKOSUKA JAPAN | Tsurumi OU1/OU2 Fuel Terminal | Consecutive | 75 | Oct-17 | Apr-20 | D1 |
| CFA YOKOSUKA JAPAN | Urago Ordinance Munitions | Consecutive | 39 | Oct-17 | Apr-20 | D1 |
| CFA YOKOSUKA JAPAN | Yokosuka Base Water System | Consecutive | 30,000 | Oct-17 | Apr-20 | T2, D3 |
| CFA OKINAWA JAPAN | Camp Shields Facility Water System | Consecutive | 613 | Dec-18 | FY21 | D1 |
| CFA OKINAWA JAPAN | White Beach Facility Water System | Consecutive | 644 | Dec-18 | FY21 | D2 |
| CFA OKINAWA JAPAN | Awase Water System | Consecutive | 15 | Dec-18 | FY21 | D1 |
| CFA OKINAWA JAPAN | Tengan Pier | Consecutive | 0 | Dec-18 | FY21 | D1 |
| NAF ATSUGI JAPAN | NAF Atsugi | Groundwater | 6,700 | Oct-18 | FY21 | T2, D2 |
| NAF MISAWA JAPAN | FLC Yokosuka, Hachinohe Fuel Terminal | Consecutive | 23 | Dec-19 | Mar-19 | D1 |
| CFA SASEBO JAPAN | Main Base | Consecutive | 6,000 | May-19 | FY21 | D3 |
| CFA SASEBO JAPAN | Akasaki | Consecutive | 114 | May-19 | FY21 | D1 |
| CFA SASEBO JAPAN | Iorizaki POL | Consecutive | 25 | May-19 | FY21 | D1 |
| CFA SASEBO JAPAN | Yokose | Consecutive | 218 | May-19 | FY21 | T1, D1 |
| CFA SASEBO JAPAN | Hario Village | Consecutive | 972 | May-19 | FY21 | D1 |
| CFA SASEBO JAPAN | Hario Shima | Consecutive | 25 | May-19 | FY21 | D1 |
| CFA SASEBO JAPAN | Maebata | Consecutive | 105 | May-19 | FY21 | D1 |

| <i>Installation Name</i> | <i>Water System</i> | <i>Source Type</i> ¹ | <i>Population Served</i> | <i>CTO Actual / Planned Dates</i> | | <i>Operator Training Requirement</i> ³ |
|---|------------------------|------------------------------------|--------------------------|--|--|---|
| | | | | <i>Most Recent Cert. to Operate</i> ² | <i>WQOC Sanitary Survey Site Visit</i> | |
| SINGAPORE AREA COORDINATOR SINGAPORE | Sembawang Water System | Consecutive | 500 | Feb-18 | Aug-20 | D1 |
| NAVY REGION SOUTHEAST | | | | | | |
| NAVSTA GUANTANAMO BAY CUBA | Desalination Plant | Surface Water | 5,848 | Jun-19 | FY21 | T3, D3 |
| AUTEC ANDROS ISLAND BAHAMAS | NUWCDETAUTEC | Groundwater Under Direct Influence | 800 | May-17 | Dec-18 | T3, D1 |

1 SOURCE TYPE DEFINITIONS.

Groundwater: Groundwater wells isolated from surface water sources

Surface Water: Rivers, lakes, streams

Groundwater Under Direct Influence: Shallow groundwater wells connected with surface water sources

Consecutive: Navy purchased water

2 CERTIFICATE TO OPERATE STATUS. Bolded date indicates full certificate to operate. All other dates indicate conditional certificate to operate.

3 OPERATOR REQUIREMENT DEFINITIONS. Each system has a letter indicating system type and a number indicating complexity, requiring varying degrees of training.

D: Drinking water Distribution system as defined by RWQB inventory.

T: Drinking water Treatment system as defined by RWQB inventory.

1: Low system complexity.

2: Medium system complexity.

3: High system complexity.

This Page Intentionally Left Blank

Appendix E: Drinking Water Systems under EPA Jurisdiction with Exceedances

Exceedance #1

Installation (System): NSA Andersen- Anderson Water Systems

Exceedance: Unapproved treatment process; Pool Time Chlorination Tabs

Notification Date: 03 January 2019

Duration: 45 days

Population Served: 200

Description of Exceedance: The operators of the water system introduced a new treatment process in lieu of the approved Hypochlorite Generator system (MIOX) without first obtaining approval from Guam EPA in violation of 22 GAR §6141.S(c). Operators used "Pool Time Chlorination Tabs (3-in-1 Formula)" which contains pesticide products. Guam EPA issued an \$83,700 fine for use of the chemicals.

Plan of Action and Milestones: CLOSED Feb 2019. The operators immediately stopped using the "Pool Time Chlorination Tabs (3-in-1 Formula)" upon the inspection on 28 Dec 2018. The water system tanks were cleaned and lines flushed, the MIOX system repaired and treatment resumed using sodium hypochlorite. Public notice was issued to customers 16 Jan 2019.

Contingency Plans to Provide Alternate Water Supplies: Contingency plans were not applicable.

Exceedance #2

Installation (System): Joint Base Anacostia Bolling (JBAB) – Anacostia

Exceedance: Undetectable disinfection residual

Notification Date: 12 February 2019 and 17 September 2019

Duration: 60 days

Population Served: 50

Description of Exceedance: January and August 2019 routine sampling results for JBAB showed greater than 5% of distribution system samples with an undetectable disinfectant residual. This marked the second consecutive month with greater than 5% of distribution system samples having an undetectable disinfectant residual. Per 40 CFR 141.72, this is a treatment technique violation triggering a Tier 2 public notification.

Plan of Action and Milestones: CLOSED on 24 Sep 2019. The hydrant that was previously used to flush the building in question was the incorrect one (maps inaccurate). The correct hydrant has since been identified allowing the building chlorine levels to rise once rigorous flushing was conducted.

Contingency Plans to Provide Alternate Water Supplies: Contingency plans were not applicable.

Exceedance #3

Installation (System): NAS Lemoore

Exceedance: Total Trihalomethane (TTHM)

Notification Date: 23 August 2018 & 09 October 2018

Duration: 180 days

Population Served: >10,000

Description of Exceedance: Exceeded the locational running annual average (LRAA) MCL limit for TTHM (80 parts per billion (ppb)) in the 4th Quarter FY18 at one location on the operations side of the base. The LRAA was 80.6 ppb. This exceedance is a continuation from 4th Quarter FY2018.

Plan of Action and Milestones: CLOSED on 6 Feb 2019. Operational Tanks 52 & 53 were drained and cleaned in October 2018. Additionally, turnover rates were altered and automatic flushers implemented in the affected areas to increase turnover. Monitoring will continue as required. Compliance with the MCL is required for four consecutive quarterly events; of a target of 2nd quarter FY2019.

Contingency Plans to Provide Alternate Water Supplies: Contingency plans were not applicable.

Exceedance #4

Installation (System): WPNSTA Earle Colts Neck Main Base

Exceedance: Total Trihalomethane (TTHM)

Notification Date: December 5, 2018

Duration: 137 days

Population Served: 1,200

Description of Exceedance: Exceeded the locational running annual average (LRAA) MCL limit for TTHM (80 parts per billion (ppb)) at both sampling locations during the 4th quarter of calendar year 2018. The running annual average returned to compliance based on samples collected in the 2nd quarter of 2019.

Plan of Action and Milestones: CLOSED on 14 Feb 2019. The water supplier, New Jersey American Water (NJAW) installed a ventilation system in their Asbury Avenue Storage tank located just outside the NW Earle fence-line, in an effort to reduce TTHM concentration in their distribution system. Additionally, NWS Earle has installed automatic flushing devices in its distribution system and is installing an aeration system in its water storage tank to supplement the NJAW Asbury Avenue storage tank ventilation system for TTHM removal.

Contingency Plans to Provide Alternate Water Supplies: Contingency plans were not applicable.